

November 1999

JASPER JR SR HIGH SCHOOL – JASPER, ALBERTA
EXECUTIVE SUMMARY

This school was built in 1952 with additions added in 1958, 1967 and 1987. Minor modernization occurred in specific areas in 1967 administration area, 1987 gymnasium and 1999 CTS shop upgrade.

The school site requires re-grading away from the school to provide proper site drainage. Concrete sidewalks and pads require repair or replacement. Access to school is poor with little parking space available. Age of school indicates problems with wood floors, windows require replacement, doors and hardware to be replaced, exterior walls require proper insulation and vapor barrier, school roof replacement to be finished as per roof report. Interior of school requires a complete modernization to bring it up to Code, provide proper learning spaces and working conditions. Mechanical and electrical systems to be upgraded to provide energy efficient system and maintenance efficient operation.

School requires reorganization of spaces to provide proper ancillary, library, administration, CTS and gathering area within the school. Modernization of school would bring the school up to standards. Reorganize areas to remedy the shortfall of instructional and non-instructional space. Gymnasium is too small for school's size and should be added to or replaced.